Outdoor unit	RXV50AV1B						
Indoor unit FTXV50AV1B							
Function				Heating season			
Cooling				Average (mandatory)	Yes		
Heating	Yes			Warmer (if designated)	No		
		Colder (if designated)	No				
	1	1	-				1
Item	Symbol	Value	Unit	Item	Symbol	Value	Unit
Design Load				Seasonal efficiency	T		
Cooling	Pdesignc	5.20	kW	Cooling	SEER	5.6	ŀ
heating / Average	Pdesignh	4.50	kW	heating / Average heating / Warmer	SCOP / A SCOP / W	3.8	ŀ
heating / Warmer heating / Colder	Pdesignh Pdesignh		kW kW	heating / Warmer heating / Colder	SCOP / W		
Fredaing / Golder	i acoigini	_	1000	reduing 7 colder	10001 70		
temperature Tj				Declared energy efficiency ratio*, at indoor temperature 27(19) °C and outdoor temperature Tj			
Tj = 35°C	Pdc	5.20	kW	Tj = 35°C	EERd	3.11	ŀ
Tj = 30°C	Pdc	3.83	kW	Tj = 30°C	EERd	4.65	ŀ
Tj = 25°C	Pdc Pdc	2.46 2.21	kW kW	Tj = 25°C Ti = 20°C	EERd EERd	6.62 8.91	ŀ
Tj = 20°C	<u> </u> Fuc	Z.Z I	IVAA	[1] - 20 C	ILLINU	0.91	<u>-</u>
and outdoor temperature Tj				Declared coefficient of performance* / Average season, at indoor temperature 20 °C and outdoor temperature Tj			
Tj = -7°C	Pdh	3.98	kW	Tj = -7°C	COPd	2.61	-
Tj = 2°C	Pdh	2.42	kW	Tj = 2°C	COPd	3.90	ŀ
Tj = 7°C	Pdh - ::	1.56	kW	Tj = 7°C	COPd	4.62	 -
Tj = 12°C	Pdh	1.99	kW	Tj = 12°C	COPd	5.67	ŀ
Tj = bivalent temperature	Pdh Pdh	3.98 3.56	kW kW	Tj = bivalent temperature	COPd COPd	2.61 2.47	ŀ
Tj = operating limit	Pun	5.50	KVV	Tj = operating limit	COPu	2.41	<u>r</u>
				Declared coefficient of performance* / Warmer season, at indoor temperature 20 °C and outdoor temperature Tj			
Tj = 2°C	Pdh		kW	Tj = 2°C	COPd		-
Tj = 7°C	Pdh		kW	Tj = 7°C	COPd		-
Tj = 12°C	Pdh		kW	Tj = 12°C	COPd		-
Tj = bivalent temperature	Pdh		kW	Tj = bivalent temperature	COPd		-
Tj = operating limit	Pdh		kW	Tj = operating limit	COPd		
				Declared coefficient of performance* / Colder season, at indoor temperature 20 °C and outdoor temperature Tj			
Tj = -7°C	Pdh		kW	Tj = -7°C	COPd		-
Tj = 2°C	Pdh		kW	Tj = 2°C	COPd		-
Tj = 7°C	Pdh		kW	Tj = 7°C	COPd		-
Tj = 12°C	Pdh		kW	Tj = 12°C	COPd		-
Tj = bivalent temperature	Pdh		kW	Tj = bivalent temperature	COPd		-
Tj = operating limit Tj = -15°C	Pdh Pdh		kW kW	Tj = operating limit Tj = -15°C	COPd COPd		į.
[]10 0	ji dii		KVV	1110-0	<u>1001 u</u>		_
Bivalent temperature				Operating limit temperature			
heating / Average	Tbiv	-7	°C	heating / Average	Tol	-10	ŀc
heating / Warmer	Tbiv		°C	heating / Warmer	Tol		°C
heating / Colder	Tbiv		°C	heating / Colder	Tol		<u>°C</u>
Constitute intermed acceptant			Cycling interval officionary				
Cycling interval capacity	Dayes		kW	Cycling interval efficiency	EERcyc		
for cooling for heating	Pcycc Pcych		kW	for cooling for heating	COPcyc		
Degradation co-efficient cooling**	Cdc	0.25	Ľ I	Degradation co-efficient cooling**	Cdh	0.25	Ĺ.
Bogradation of Smolent Scenning	1000	0.20		Bogradation of emoletic econing		10.20	
				Annual electricity consumption			
off mode	Poff	0.001	kW	Cooling	QCE	325	kWh/a
	OII				0_		
standby mode	^P sb	0.001	kW	heating / Average	QHE	1,658	kWh/a
thermostat-off mode		0.045	1.307	hasting (NA)			1-10/1-/-
thermostat-on mode	PTO	0.045	kW	heating / Warmer	QHE		kWh/a
crankcase heater mode		0.0	kW	heating / Colder			kWh/a
Crankease ricater mode	PCK	0.0	IXVV	incaring 7 Golder	QHE		KVVII/G
		1					
			Other items				
fixed	N	l		Sound power level (indoor/outdoor)	ĿWA	53 / 68	db(A)
L	NI.			Clabal	1	0.007.5	
staged	IN	l		Global warming potential	GWP	2,087.5	kgCO2eq.
variable	Y	1		Rated air flow (indoor/outdoor)	L	/ 53.3	m ³ /min
		ı		. account non (maconoutacor)		. 00.0	ırn /min
	DAIKIN EUROPE I	ı v					
Contact details for obtaining more	Zandvoordestraat						
information B-8400 Oostende							
	Belgium						

for staged capacity units, two values divided by a slash (/) will be declared in each box in the section 'Declared capacity of the unit' and 'Declared EER/COP' of the unit.

** if default Cd = 0,25 is chosen then (results from) cycling tests are not required. Otherwise either the heating of cooling cycling test value is required.